



Report No : -CIPL/NSK/R/04214/26
ULR No.: -TC163882600004214F

Date :-09-09-2026

TEST REPORT

Client Name :- Adinath Education Society's English Medium Pre- primary, Primary, High School
Address :- Mahavir Nagar, College Road, Malegaon camp, Malegaon Nashik, MAHARASHTRA-423203
Sample Description :- Drinking Water
Sample Quantity/Packing :- 1.0 Lit. /Plastic Bottle (Unsealed)
Testing Location :- Plot No. B-45, Satpur MIDC, NICE Area, Nashik-422007, Maharashtra.
Job No :- 090814
Date of Receipt of Material :- 08-09-2026
Date of performance of test :- 08-09-2026 To 09-09-2026
Temp. At Time Of Test :- 26°C
Humidity At Time Of Test:- 46%

SR. NO.	Test	UNIT	RESULTS	ACCEPTABLE LIMITS AS PER IS10500:2012 RA-2023	TEST METHOD
1	Colour	Hazen	0.20	<5.00	IS 3025:2021 Part 4
2	Odour		Agreeable	Agreeable	IS 3025:2018 Part 5
3	Turbidity	NTU	<1	<1.00	IS 3025:2023 Part 10
4	Taste	--	Agreeable	Agreeable	IS 3025:2017 Part 7
5	Total Dissolved Solids	mg/lit.	78.00	<500.00	IS 3025:2023 Part 16
6	pH	--	6.91	6.5-8.5	IS 3025:2022 Part 11
7	Total Hardness as CaCO ₃	mg/lit.	66.00	<200.00	IS 3025:2019 Part 21
8	Total Alkalinity as CaCO ₃	mg/lit.	10.00	<200.00	APHA 24 th Edition 2320 B
9	Chlorides as Cl	mg/lit.	14.89	<250.00	IS 3025:2025 Part 32
10	Sulphate as SO ₄	mg/lit.	21.66	<200.00	IS 3025 (Part 24/Sec 1) 2022



h2am

Report No : -CIPL/NSK/R/04214/26
1 of 2





SR. NO.	Test	UNIT	RESULTS	ACCEPTABLE LIMITS AS PER IS10500:2012 RA-2023	TEST METHOD
11	Nitrate as NO ₃ -H	mg/lit.	2.87	<45.00	IS 3025:2019 Part 34
12	Fluoride as F	mg/lit.	<1	<1.00	APHA 24th Edition 4500 F D
13	Calcium Hardness CaCO ₃	mg/lit.	24.00 (Ca=9.61)	No limit for Calcium Hardness. For Calcium limit is <75.	APHA 24th Edition 3500 Ca B
14	Magnesium as Mg	mg/lit.	10.21	<30.00	APHA 24 th Edition 3500-Mg B
15	Iron	mg/lit.	0.02	<0.3	APHA 24 th Edition 3500 Fe B

REMARKS: Considering Uncertainty of measurements sample is potable with Respect to above tested Parameters as per IS 10500:2012 RA 2023 only.

Note :-1) The reported results are related to the sample provided by the client & valid at environment condition in which test performed.

2) This report refers only to the particular sample submitted to lab for the Test

3) Report shall not be reproduced except in full without prior written permission of Civil Tech India Pvt. Ltd.

4) This report is invalid without paper seal of Civil Tech India Pvt. Ltd.

For Civil Tech India Pvt.Ltd.

Reviewed & Authorised Signatory
Ganesh Raykar



Report No : -CIPL/NSK/R/04214/26

2 of 2





Report No : -CIPL/NSK/R/090814/26

Date :-09-09-2026

TEST REPORT

Client Name :- Adinath Education Society's English Medium Pre- primary, Primary, High School
Address :- Mahavir Nagar, College Road, Malegaon camp, Malegaon Nashik,
Sample Description :- Drinking Water
Sample Quantity/Packing :- 250ml sterilized Bottle
Testing Location :- Plot No. B-45, Satpur MIDC, NICE Area, Nashik-422007, Maharashtra.
Job No :- 090814
Date of Receipt of Material :- 08-09-2026 **Date of performance of test :-** 08-09-2026 To 09-09-2026
Temp. At Time Of Test :- 27°C **Humidity At Time Of Test:-** 46%

SR. NO.	Test	UNIT	RESULTS	ACCEPTABLE LIMITS AS PER IS10500:2012 RA-2023	TEST METHOD
Bacteriological Parameters					
01	Total Coliform	/100 ml	Absent	Absent	IS 15185:2016
02	<i>Escherichia Coli</i>	/100 ml	Absent	Absent	IS 15185:2016

REMARKS: As per results obtained are complying with IS10500:2012 RA-2023, above water sample is bacteriologically potable.

Note :-1) The reported results are related to the sample provided by the client & valid at environment condition in which test performed.


2) This report refers only to the particular sample submitted to lab for the Test

3) Report shall not be reproduced except in full without prior written permission of Civil Tech India Pvt. Ltd.

4) This report is invalid without paper seal of Civil Tech India Pvt. Ltd.

For Civil Tech India Pvt.Ltd.

Reviewed & Authorised Signatory
Ganesh Raykar



Report No : -CIPL/NSK/R/090814/26
1 of 1



मालेगाव महानगरपालिका, मालेगाव

स्वच्छता विभाग

फोन नं. (02554) 231900, 231800, 231801

फॅक्स नं. 230894, आयुक्त कार्यालय


जा.क्र./मामनपा/स्वच्छता/६६८/2026

दिनांक:- 2९/०९/2026

स्वच्छतेचा दाखला

दाखला देण्यात येतो की, मालेगाव महानगरपालिका मालेगाव, प्रभाग कार्यालय क्रं.01 च्या हद्दीतील आदिनाथ एज्युकेशन सोसायटी इंग्लिश मेडियम स्कूल मालेगाव कॅम्प या शाळेच्या आवारात संवधीत स्वच्छता निरीक्षक यांनी स्वच्छते वावत समक्ष पाहणी केली असता सार्वजनिक आरोग्याच्या दृष्टीकोनातून स्वच्छता संवंधी योग्य ती काळजी घेतली जाते.

सदर दाखला चेअमरन - आदिनाथ एज्युकेशन सोसायटी इंग्लिश मेडियम स्कूल मालेगाव कॅम्प, ता. मालेगाव, जि. नाशिक यांचे दि. 21/09/2026 च्या विनंती अर्जानुसार देण्यात येत आहे.



(Signature)
प्रमुख स्वच्छता निरीक्षक

मालेगाव महानगरपालिका, मालेगाव



Malegaon Municipal Corporation, Malegaon
sanitation department

Phone No. (02554) 231900,231800,231801

Fax No. 230894, Commissioner's Office

J.No. /MMC/Sanitation / 668 /2026

Date:- 29/09/2026

Certificate of cleanliness

It is hereby certified that the cleanliness of the premises of Adinath Education Society English Medium School Malegaon Camp, Malegaon, Ward Office No. 01, Malegaon Municipal Corporation, has been inspected by the concerned sanitation inspector and proper care is taken regarding cleanliness from the perspective of public health.

This certificate is being issued in accordance with the request of the Chairman - Adinath Education Society English Medium School Malegaon Camp, Tal. Malegaon, Dist. Nashik dated 21/09/2026.



Chief Sanitation Inspector

Malegaon Municipal Corporation, Malegaon